



GASMARK SCHEDULE



Certificate Holder
Oceania Gas Safety

A.B.N.:
25 Liverpool Street, Tuakau, Waikato 2121 New Zealand

Manufacturer
Refer to Certificate Holder

Standard
AS4629-2005 (Amdt 2)
Automatic shut off valves and vent valves

Certificate No. GMK10743

Certification Date: 12 April 2021

Expiry Date: 11 April 2026

First Certified: 12 April 2021

Distributor	Brand Name	Model ID	Gas Type	Product Description	Classification	Maximum Operating Pressure	Temperature	Variations	Installation Type	Inlet/Outlet
Refer to Certificate Holder	Goldseal	GSV15	Component	Safety shut-off valve	Class 1	36 kPa	-20°C to 60°C	Refer to Certificate Holder	Not inverted	Rp 1/2
Refer to Certificate Holder	Goldseal	GSV20	Component	Safety shut-off valve	Class 1	36 kPa	-20°C to 60°C	Refer to Certificate Holder	Not inverted	Rp 3/4
Refer to Certificate Holder	Goldseal	GSV25	Component	Safety shut-off valve	Class 1	36 kPa	-20°C to 60°C	Refer to Certificate Holder	Not inverted	Rp 1
Refer to Certificate Holder	Goldseal	GSV32	Component	Safety shut-off valve	Class 1	20 kPa	-20°C to 60°C	Refer to Certificate Holder	Not inverted	Rp 1 1/4
Refer to Certificate Holder	Goldseal	GSV40	Component	Safety shut-off valve	Class 1	20 kPa	-20°C to 60°C	Refer to Certificate Holder	Not inverted	Rp 1 1/2
Refer to Certificate Holder	Goldseal	GSV50	Component	Safety shut-off valve	Class 1	20 kPa	-20°C to 60°C	Refer to Certificate Holder	Not inverted	Rp 2

END RECORD

END RECORD

CEO, The IAPMO Group